

**NOTES**


- Temporary workspace of approximately 30 x 30 metres (m) is required in addition to the existing right-of-way.
- Additional temporary workspace of approximately 30 x 100 m for stringing locations is also required.
- Right-of-way widths vary from approximately 25-70 m and up to 90 m for the crossing of the North Saskatchewan River.
- Option 2B requires two crossings of the North Saskatchewan River.



**LEGEND**

- Existing Substation
- Potential Transmission Line - Option 1A
- Potential Transmission Line - Option 2A
- Potential Transmission Line - Option 2B
- Potential Salvage of Existing Transmission Line
- Existing Transmission Line
- Potential Right of Way Boundary
- Proposed Customer Substation
- Temporary Workspace
- Residence
- Wellsite
- Municipal or County Boundary
- Pipeline
- Railway
- Road
- Crown Land
- Urban Area
- Water Body

NO: 35035824  
 DRAWN: SG - AL  
 FILE NO.: XXXXXXX  
 REVISION: 0.01.05  
 AL FOLDER: Dow Fort Saskatchewan Load Project  
**DATE: 2024-09-24**



**DETAIL PHOTO DP1**



**POTENTIAL**

Dow Fort Saskatchewan Load Project

Service Layer Credits: Source: Esri, Maxar, Earthstar Geographics, and the GIS User Community  
 Although there is no reason to believe that there are any errors associated with the data used to generate this product or in the product itself, users of these data are advised that errors in the data may be present.